



SECTION - A

NOTES:

1. PRECAST AND CAST IN PLACE BASE SHALL BE A MINIMUM OF 6 FT IN WIDTH.
2. CAST IN PLACE CONCRETE BASE SHALL BE 4,000 PSI.
3. TESTING SHALL BE PER SPEC SECTION.
4. MANHOLE BASE TO BE SET ON UNDISTURBED MATERIAL, IF OVER CUT, FILL WITH CRUSHED ROCK OR CONCRETE.
5. PRECAST BASES TO HAVE FORMED INVERTS AND HAVE RESILIENT RUBBER COUPLING (AS REQ'D.) WITH STAINLESS STEEL CLAMPS OVER PIPE.

DETAIL DEPICTS DIMENSIONAL REQUIREMENTS. THE ARCHITECT/ENGINEER ASSUMES RESPONSIBILITY FOR THE APPROPRIATE USE OF THIS STANDARDS.



STANDARD W.W. PRECAST MANHOLE

STANDARD CONSTRUCTION DETAILS
WASTEWATER

DATE:
MARCH 2007

SCALE:
NTS

SHEET:
SD-SS01