



NOTES:

1. BOTTOM PIPE INVERT SHALL NOT BE MORE THAN 12" ABOVE THE BASE INVERT ELEVATION.
2. IF THERE IS A DIFFERENCE IN GRADE CHANGE, A DROP MANHOLE SHALL BE REQUIRED.

DETAIL DEPICTS DIMENSIONAL REQUIREMENTS. THE ARCHITECT/ENGINEER ASSUMES RESPONSIBILITY FOR THE APPROPRIATE USE OF THIS STANDARDS.



PRECAST MANHOLE WITH DROP INLET  
ON PRECAST BASE

STANDARD CONSTRUCTION DETAILS  
WASTEWATER

DATE:  
MARCH 2007

SCALE:  
NTS

SHEET:  
SD-SS02