



NOTES:

1. MORTAR BEDS SHALL NOT EXCEED ONE INCH.
2. SUBGRADE AND BASE MATERIALS SHALL BE COMPACTED TO 95% AND 100% DENSITIES, RESPECTIVELY. COMPACTION SHALL BE BY MECHANICAL TAMPING TO THE DENSITIES SPECIFIED.

DETAIL DEPICTS DIMENSIONAL REQUIREMENTS. THE ARCHITECT/ENGINEER ASSUMES RESPONSIBILITY FOR THE APPROPRIATE USE OF THIS STANDARDS.



MINOR MANHOLE ADJUSTMENT DETAIL

STANDARD CONSTRUCTION DETAILS
WASTEWATER

DATE:
MARCH 2007

SCALE:
NTS

SHEET:
SD-SS06