



PLAN

NOTE:

1. INSULATE ALL EXPOSED BACKFLOW PREVENTER AND AIR RELEASE PIPING. OR PROVIDE INSULATED ENCLOSURE BOX WITH SEALED PORTS.
2. PROVIDE TWO (2) HOT-DIP GALVANIZED STEEL PIPE SUPPORTS UNDERNEATH THE BACKFLOW PREVENTER.

DETAIL DEPICTS DIMENSIONAL REQUIREMENTS. THE ARCHITECT/ENGINEER ASSUMES RESPONSIBILITY FOR THE APPROPRIATE USE OF THIS STANDARDS.



BACKFLOW PREVENTER

STANDARD CONSTRUCTION DETAILS
WATER

DATE:
MARCH 2007

SCALE:
NTS

SHEET:
SD-W11